



DEPARTMENT OF REGULATORY AND ECONOMIC RESOURCES (RER)
BOARD AND CODE ADMINISTRATION DIVISION

MIAMI-DADE COUNTY
PRODUCT CONTROL SECTION
11805 SW 26 Street, Room 208
Miami, Florida 33175-2474
T (786) 315-2590 F (786) 315-2599
www.miamidade.gov/

NOTICE OF ACCEPTANCE (NOA)

Curacreto, LLC
5850 San Felipe Street, Suite 500
Houston, TX 77057

SCOPE:

This NOA is being issued under the applicable rules and regulations governing the use of construction materials. The documentation submitted has been reviewed and accepted by Miami-Dade County RER - Product Control Section to be used in Miami Dade County and other areas where allowed by the Authority Having Jurisdiction (AHJ).

This NOA shall not be valid after the expiration date stated below. The Miami-Dade County Product Control Section (In Miami Dade County) and/or the AHJ (in areas other than Miami Dade County) reserve the right to have this product or material tested for quality assurance purposes. If this product or material fails to perform in the accepted manner, the manufacturer will incur the expense of such testing and the AHJ may immediately revoke, modify, or suspend the use of such product or material within their jurisdiction. RER reserves the right to revoke this acceptance, if it is determined by Miami-Dade County Product Control Section that this product or material fails to meet the requirements of the applicable building code.

This product is approved as described herein, and has been designed to comply with the Florida Building Code including the High Velocity Hurricane Zone of the Florida Building Code.

DESCRIPTION: TESTAROSSO SBS SP FR WG over LWC Decks

LABELING: Each unit shall bear a permanent label with the manufacturer's name or logo, city, state and following statement: "Miami-Dade County Product Control Approved", unless otherwise noted herein.

RENEWAL of this NOA shall be considered after a renewal application has been filed and there has been no change in the applicable building code negatively affecting the performance of this product.

TERMINATION of this NOA will occur after the expiration date or if there has been a revision or change in the materials, use, and/or manufacture of the product or process. Misuse of this NOA as an endorsement of any product, for sales, advertising or any other purposes shall automatically terminate this NOA. Failure to comply with any section of this NOA shall be cause for termination and removal of NOA.

ADVERTISEMENT: The NOA number preceded by the words Miami-Dade County, Florida, and followed by the expiration date may be displayed in advertising literature. If any portion of the NOA is displayed, then it shall be done in its entirety.

INSPECTION: A copy of this entire NOA shall be provided to the user by the manufacturer or its distributors and shall be available for inspection at the job site at the request of the Building Official.

This NOA consists of pages 1 through 4.
The submitted documentation was reviewed by Hamley Pacheco, P.E.



NOA No: 18-0604.06
Expiration Date: 02/07/24
Approval Date: 02/07/19
Page 1 of 4

ROOFING SYSTEM APPROVAL

Category:	Roofing
Sub-Category:	Modified Bitumen
Material:	SBS
Deck Type:	Lightweight concrete
Maximum Design Pressure:	-207.5 psf

TRADE NAMES OF PRODUCTS MANUFACTURED OR LABELED BY APPLICANT:

TABLE 1

<u>Product</u>	<u>Dimensions</u>	<u>Test Specification</u>	<u>Product Description</u>
Testarosso SBS BFG 300 S	39- ³ / ₈ " x 32.81' (1m x 10m)	ASTM D 6163 Type I	SBS modified bitumen waterproofing membrane with a sanded finish. It consists of one layer of fiber glass mat reinforcement sandwiched by SBS rubber in a high penetration index asphalt mixture.
Testarosso SBS FR SP 400 WG	39- ³ / ₈ " x 32.81' (1m x 10m)	ASTM D 6164 Type I	SBS modified bitumen waterproofing membrane with a granulated finish. It consists of one layer of polyester mat reinforcement sandwiched by SBS rubber in a high penetration index asphalt mixture.
Testarosso SBS SP 400 Aluminium Flake	39- ³ / ₈ " x 32.81' (1m x 10m)	ASTM D 6164 Type I	SBS modified bitumen waterproofing membrane with an aluminum flake finish. It consists of one layer of polyester mat reinforcement sandwiched by SBS rubber in a high penetration index asphalt mixture.
Testarosso SBS SP 400 WG	39- ³ / ₈ " x 32.81' (1m x 10m)	ASTM D 6164 Type I	SBS modified bitumen waterproofing membrane with a granulated finish. It consists of one layer of polyester mat reinforcement sandwiched by SBS rubber in a high penetration index asphalt mixture.

EVIDENCE SUBMITTED:

<u>Test Agency</u>	<u>Test Identifier</u>	<u>Description</u>	<u>Date</u>
PRI Construction Material Technology	CURA-001-02-03	ASTM D 6163	12/27/17
	CURA-004-02-06	ASTM D 6164	02/05/18
	CURA-006-02-01	ASTM D 6164	04/27/18
	CURA-004-02-08	ASTM D 6164	04/27/18
Atlantic & Caribbean Roof Consulting, LLC	ACRC 18-007	TAS 114-95 Appendix D	08/23/18
	ACRC 18-008	TAS 114-95 Appendix D	08/23/18
	ACRC 17-012	TAS 114-95 Appendix D	08/23/18



APPROVED ASSEMBLIES

Membrane Type:	SBS
Deck Type 4:	Lightweight Concrete, Non-Insulated
Deck Description:	Minimum 2” of min.462 psi Cellular Lightweight Insulating Concrete is cast over structural concrete deck. Lightweight Concrete should record a Minimum Characteristic Resistance Force (MCRF) of 62.81 lbf when tested with OMG 1.75” Base Sheet Fasteners in accordance with TAS 105.
System Type F:	Base sheet adhered to substrate
Deck:	Minimum 2500 psi structural concrete

All General and System Limitations apply. Roof accessories not listed in Table 1 of this NOA are not approved and shall not be installed unless said accessories demonstrate compliance with prescriptive Florida Building Code requirements and are field fabricated utilizing the approved membranes listed in Table 1.

Base/Ply Sheet:	One ply of Testarosso SBS BFG 300 S torch applied to ASTM D 41 primed lightweight insulating concrete.
Membrane:	One ply of Testarosso SBS FR SP 400 WG torch applied to the base sheet with a minimum 4” wide side lap. Or One ply of Testarosso SBS SP 400 WG torch applied to the base sheet with a minimum 4” wide side lap. Or One ply of Testarosso SBS SP 400 Aluminium Flake torch applied to the base sheet with a minimum 4” wide side lap.
Maximum Design Pressure:	- 207.5 psf (See General Limitation #9).



LIGHTWEIGHT INSULATING CONCRETE SYSTEM LIMITATIONS:

1. If mechanical attachment to the structural deck through the lightweight insulating concrete is proposed, a field withdrawal resistance testing shall be performed to determine equivalent or enhanced fastener patterns and density. All testing and fastening design shall be in compliance with Testing Application Standard TAS 105 and Roofing Application Standard RAS 117; calculations shall be signed and sealed by a Florida Registered Engineer, Architect, or Registered Roof Consultant.
2. For steel deck application where specific deck construction is not referenced: The deck shall be a minimum 22 gage attached with 5/8" puddle welds with weld washers at every flute with maximum deck spans of 5 ft. o.c.
3. For systems where specific lightweight insulating concrete is not referenced, the minimum design mix shall be a minimum of 300 psi.

GENERAL LIMITATIONS:

1. Fire classification is not part of this acceptance, refer to a current Approved Roofing Materials Directory for fire ratings of this product.
2. Insulation may be installed in multiple layers. The first layer shall be attached in compliance with Product Control Approval guidelines. All other layers shall be adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq., or mechanically attached using the fastening pattern of the top layer
3. All standard panel sizes are acceptable for mechanical attachment. When applied in approved asphalt, panel size shall be 4' x 4' maximum.
4. An overlay and/or recovery board insulation panel is required on all applications over closed cell foam insulations when the base sheet is fully mopped. If no recovery board is used the base sheet shall be applied using spot mopping with approved asphalt, 12" diameter circles, 24" o.c.; or strip mopped 8" ribbons in three rows, one at each sidelap and one down the center of the sheet allowing a continuous area of ventilation. Encircling of the strips is not acceptable. A 6" break shall be placed every 12' in each ribbon to allow cross ventilation. Asphalt application of either system shall be at a minimum rate of 12 lbs./sq. **Note: Spot attached systems shall be limited to a maximum design pressure of -45 psf.**
5. Fastener spacing for insulation attachment is based on a Minimum Characteristic Force (F') value of 275 lbf., as tested in compliance with Testing Application Standard TAS 105. If the fastener value, as field-tested, are below 275 lbf. insulation attachment shall not be acceptable.
6. Fastener spacing for mechanical attachment of anchor/base sheet or membrane attachment is based on a minimum fastener resistance value in conjunction with the maximum design value listed within a specific system. Should the fastener resistance be less than that required, as determined by the Building Official, a revised fastener spacing, prepared, signed and sealed by a Florida Registered Engineer, Architect, or Registered Roof Consultant may be submitted. Said revised fastener spacing shall utilize the withdrawal resistance value taken from Testing Application Standards TAS 105 and calculations in compliance with Roofing Application Standard RAS 117.
7. Perimeter and corner areas shall comply with the enhanced uplift pressure requirements of these areas. Fastener densities shall be increased for both insulation and base sheet as calculated in compliance with Roofing Application Standard RAS 117. Calculations prepared, signed and sealed by a Florida registered Professional Engineer, Registered Architect, or Registered Roof Consultant **(When this limitation is specifically referred within this NOA, General Limitation #9 will not be applicable.)**
8. All attachment and sizing of perimeter nailers, metal profile, and/or flashing termination designs shall conform with Roofing Application Standard RAS 111 and applicable wind load requirements.
9. The maximum designed pressure limitation listed shall be applicable to all roof pressure zones (i.e. field, perimeters, and corners). Neither rational analysis, nor extrapolation shall be permitted for enhanced fastening at enhanced pressure zones (i.e. perimeters, extended corners and corners). **(When this limitation is specifically referred within this NOA, General Limitation #7 will not be applicable.)**
10. All products listed herein shall have a quality assurance audit in accordance with the Florida Building Code and Rule 61G20-3 of the Florida Administrative Code.

END OF THIS ACCEPTANCE



NOA No: 18-0604.06
Expiration Date: 02/07/24
Approval Date: 02/07/19
Page 4 of 4